AMENDMENT NO. 1 JULY 2015
TO
IS 8130 : 2013 CONDUCTORS FOR INSULATED ELECTRIC CABLES AND FLEXIBLE CORDS — SPECIFICATION

(Second Revision)

(*Page* 2, *clause* **6.1.3**) **—** Substitute '1.5 mm^2 up to and including 35 mm^2' *for* '10 mm^2 up to and including 35 mm^2'.

[*Page* 3, *clause* **7.2.1** (a) *and* (b)] **—** Substitute '**4.1**' *for* '**3.1**'.

(*Page* 4, *Table* 1, *col* 5) — Substitute the following for the existing, against respective Sl Nos.

Sl No.	***Aluminium Conductors*** **Circular or Shaped** Ω/km
(1)	(5)
iv)	18.1
v)	12.1
vi)	7.41
vii)	4.61
viii)	3.08

(*Page* 4, *Table* 1, *footnote*[2)]) **—** Substitute '1.5 mm^2 up to and including 35 mm^2' *for* '10 mm^2 up to and including 35 mm^2'.

(ETD 09)

Publication Unit, BIS, New Delhi, India